

District Feasibility Assessment for Ground Source Heat Pump System

Prepared for:
**Otter Tail Power Company &
Bemidji State University**

Submitted 2021-1-11 to:

215 South Cascade Street
PO Box 496
Fergus Falls, MN

ATTN: Mr. Roger Garton



GEOptimize

220 Portage Avenue, #1410, Winnipeg, MB R3C 0A5

4

5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45

The information and opinions expressed in this report are prepared for the benefit of Otter Tail Power Company (OTPCO) and Bemidji State University (BSU) for the sole purpose of evaluating the energy savings and cost avoidance estimates of the projects identified herein. No other party may use or rely upon the report or any portion thereof without the express written consent of GEOptimize Inc. GEOptimize accepts no responsibility for the accuracy of the report to parties other than OTPCO and BSU. The material contained in this report reflects the best judgment of GEOptimize with the information available at the time of preparation. Inaccurate, incorrect, or invalid information supplied to us for the purpose of preparing this report may affect the findings, statements or conclusions expressed herein, for which GEOptimize cannot be held responsible.

46 Executive Summary

47

48 Bemidji State University (BSU) is a public state university located in Bemidji, MN with over 5,400 students and 23 buildings on
49 campus with 1,450,000 ft² of floor area. BSU has embarked on a plan to achieve carbon neutrality by 2050. GEOptimize was
50 retained to determine the feasibility of installing a district ground source heat pump (GSHP) system in the facility and
51 comparing it to continuing to operate with the current central plant natural gas heating and electric cooling system.

52

53 To quantify the individual buildings space heating and cooling loads, previously constructed building energy models using
54 Trane Trace 700 V6.3.4.0 were used. Based on the various buildings subdivided space usage, hourly energy loads from the
55 existing energy models were scaled either up or down depending on the floor area difference and aggregated to create a new
56 building energy profile. This method was applied to each of the 23 buildings in this analysis. The aggregated modelled energy
57 loads were calibrated to the current energy bills to within 7% accuracy.

58

59 Individual energy load profiles were then optimized by using energy efficiency measures of lighting upgrades and energy
60 recovery ventilators (ERV's). ERV's transfer energy from exhaust air to pre-heat or pre-cool incoming outdoor ventilation air
61 which reduce the heating and cooling load in the buildings. More efficient lighting and lighting controls reduce cooling load as
62 less energy is added to the space and also increase heating loads. These efficiency measures allow for a reduction in overall
63 space heating and cooling while balancing the energy loads. This results in a reduced capital cost for ground heat
64 exchangers (GHX) and reduced energy consumption.

65

66 The energy load profiles were used to model the size and performance of the GHX using the Ground Loop Design (GLD)
67 2016 software and thermal properties from the soil profile on campus. A horizontal directionally drilled (HDD) GHX was
68 determined to be the most cost effective due to abundant land area on the campus and relatively low-cost drilling rates.
69 Additionally, one vertical GHX and two water well heat exchangers were utilized in this study. Based on various interviews
70 with the BSU staff and information sharing, a building priority list was developed to portion the capital cost required to begin
71 the project. A modular construction process was applied by utilizing energy transfer pipe technology.

72

73 An energy transfer pipe moves energy from one building that is rejecting heat to the system (cooling) to another building that
74 is extracting energy from the system (heating) and can be thought of as a conveyor belt. It consists of a single uninsulated
75 plastic pipe with connections to buildings and GHX modules that allow for thermal energy storage and either heat extraction
76 or heat rejection. Discretionary heating or cooling loads such as wastewater heat exchangers, surface water heat
77 exchangers, and snow melt systems can be integrated to help manage the energy transfer pipe temperatures and reduce the
78 capital costs while increasing the efficiency of the system. The energy transfer pipe system is an opportunistic technology that
79 can take advantage of unique features of the site and buildings on the campus.

80

81 Based on the methodology described, in depth financial calculations were performed for each construction step based on the
82 GHX cost, distribution piping cost, incentives, and energy cost savings. Two in depth analyses were performed, one with
83 efficiency measures applied to the buildings and one without. The analysis without efficiency measures was deemed
84 unfeasible due to a 40% greater GHX cost.

85

86 The total incremental cost for the district GSHP system including efficiency measure upgrades is \$10,006,269 with annual
87 energy cost savings of \$450,275 once the project is complete (Table 1). Since the construction process is split into steps, this
88 allows for compounding energy savings as more buildings are added to the energy transfer pipe.

89

90 The environmental impact from carbon dioxide (CO₂) emissions was one of the main driving factors for this study. Based on
91 the current natural gas and electricity consumption as well as the CO₂ emissions intensity for the electrical grid (1.69
92 lbs/kWh), the estimated current annual CO₂ emissions from BSU is 14,102 metric tonnes (MT). Electrifying the campus would
93 eliminate 98% of on-site CO₂ emissions due to the elimination of burning natural gas for heating. The estimated reduction in
94 total CO₂ emissions considering the carbon intensity of electricity, once the full campus retrofit is complete including efficiency
95 measure upgrades is 42% to a total of 8,181 MT's annually. Additionally, BSU can purchase \$5,700 worth of RECs to offset
96 the CO₂ emissions from their campus electricity consumption.

97

98 Table 1: Estimated capital and energy costs broken into recommended construction steps.

	Construction Steps	GHX Cost	Cooling Equipment Cost	ERV Cost	Lighting Upgrade Cost	Incentives	Incremental Capital Cost	Energy Cost Savings
A	Deputy Hall	\$440,748	\$297,000	\$157,312	\$0	\$184,800	\$710,260	\$30,304
B	Bangsburg Hall + Phase 1 ETP	\$333,382	\$235,950	\$173,756	\$86,878	\$147,876	\$682,090	\$25,877
C	Bensen Hall	\$100,188	\$141,900	\$106,684	\$53,342	\$99,503	\$302,611	\$17,344
D	Hobson Memorial Union	\$228,648	\$158,400	\$153,512	\$76,756	\$118,932	\$498,384	\$34,596
E	Heating Plant	\$23,184	\$47,850	\$40,634	\$20,317	\$34,814	\$97,171	\$5,967
F	Chet Anderson Stadium	\$0	\$7,500	\$900	\$450	\$5,162	\$3,688	\$90
G	PE complex + Phase 2 ETP	\$854,496	\$503,250	\$218,855	\$121,586	\$256,071	\$1,442,116	\$32,711
H	Gillett Wellness Center	\$577,080	\$448,800	\$171,530	\$0	\$212,300	\$985,110	\$28,942
I	Sattgast Hall	\$312,480	\$275,550	\$142,029	\$0	\$151,800	\$578,259	\$9,983
J	AC Clark Library	\$30,000	\$178,200	\$142,924	\$0	\$117,700	\$233,424	\$11,046
K	Central Receiving + Phase 3 ETP	\$144,556	\$34,650	\$16,160	\$8,080	\$21,609	\$181,837	\$2,739
L	American Indian Resource Center	\$79,380	\$31,350	\$20,776	\$10,388	\$20,240	\$121,654	\$2,837
M	Bridgeman Hall	\$84,420	\$85,800	\$0	\$33,772	\$59,458	\$144,534	\$9,884
N	Decker Hall	\$94,500	\$75,900	\$29,424	\$29,424	\$50,193	\$179,055	\$7,655
O	Memorial Hall	\$130,000	\$151,800	\$0	\$53,893	\$117,301	\$218,392	\$23,322
P	Walnut Hall	\$153,720	\$138,600	\$114,334	\$0	\$73,700	\$332,954	\$15,190
Q	Cedar Hall	\$124,740	\$92,400	\$78,266	\$39,133	\$56,988	\$277,551	\$15,145
R	Birch Hall	\$196,560	\$145,200	\$0	\$62,184	\$90,586	\$313,358	\$24,066
S	Linden Hall	\$214,200	\$146,850	\$135,130	\$67,565	\$94,723	\$469,022	\$25,274
T	Oak Hall	\$406,980	\$280,500	\$257,100	\$128,550	\$182,678	\$890,452	\$47,304
U	Tamarack Hall	\$278,460	\$206,250	\$176,820	\$88,410	\$128,628	\$621,312	\$34,215
V	Pine Hall	\$160,020	\$117,150	\$100,528	\$50,264	\$73,095	\$354,867	\$19,452
W	Hagg-Sauer Hall	\$265,860	\$240,900	\$0	\$0	\$138,592	\$368,168	\$26,335
	Total	\$5,233,602	\$4,041,750	\$2,236,674	\$930,992	\$2,436,749	\$10,006,269	\$450,275

99

100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154

Executive Summary	4
List of Figures.....	7
List of Tables.....	8
List of Abbreviations.....	9
1. Introduction.....	10
2. Utility history.....	10
2.1. Efficiencies	11
3. Methodology.....	12
3.1. Space heating and cooling block loads	12
3.2. Energy efficiency measures.....	13
3.3. GLD numerical modelling	15
3.4. Building order selection	16
3.5. Energy reduction calculations.....	17
4. GSHP system integration	18
4.1. Distribution system	18
4.1.1. Exhaust air energy recovery	18
4.2. Heating and cooling equipment.....	19
4.3. GHX.....	19
4.3.1. Water wells	22
4.3.2. Surface water heat exchanger	23
5. District system configuration.....	24
5.1. Central energy plants.....	25
5.1.1. GHX connections to central energy plant.....	25
5.1.2. Distribution piping	25
5.2. Energy sharing system	26
5.2.1. System flow rates.....	27
5.2.2. Addition of discretionary heating and cooling loads	29
5.2.3. Expanding the energy sharing system.....	30
5.3. Summary	31
6. System Implementation.....	33
6.1. Performance and monitoring	38
6.2. Discretionary loads	39
6.2.1. Auxiliary gas boilers	40
6.2.2. Wastewater energy transfer	40
6.2.3. Heat Rejection	41
6.2.4. Combined heat and power.....	41
7. Economics.....	41
8. Environmental impact.....	43
8.1. Carbon Intensity.....	44
8.2. Carbon Tax.....	46
9. Closure.....	46

155 **List of Figures**

156

157 Figure 1: Regression between average monthly heating degree day/day and therms/day..... 12

158 Figure 2: Monthly peak and total cooling and heating load based on hourly calculations for the Bangsburg Fine Arts Complex.
159 13

160 Figure 3: Energy recovery ventilation system 13

161 Figure 4: Bangsburg Fine Arts Complex energy profile with ERV..... 14

162 Figure 5: Bangsburg Fine Arts Complex energy profile with lighting upgrades..... 14

163 Figure 6: Bangsburg Fine Arts Complex energy profile with ERV and lighting upgrades..... 15

164 Figure 7: Typical vertical ground heat exchanger pipe parameters along with solution properties and design system flow rate.
165 16

166 Figure 8: Visual representation of horizontal directionally drilled boreholes..... 16

167 Figure 9: External modular mechanical room to house water to water heat pumps, and circulation pumps can possibly be
168 located near the campus buildings..... 19

169 Figure 10: Key drilling sites for the HDD GHX 21

170 Figure 11: Transferring energy between the ETP and an aquifer can be accomplished with supply / return well pair and a heat
171 exchanger in a mechanical room or with the installation of a heat exchanger located in the well casing. 23

172 Figure 12: HDPE slinky surface water heat exchanger being sunk to the bottom of a pond..... 24

173 Figure 13: Stainless steel plate surface water heat exchanger..... 24

174 Figure 14: With a central energy plant all boreholes are connected to the heat pump in the central plant. 25

175 Figure 15: Hot and chilled water is delivered to all connected buildings. The pumps and piping system is designed to
176 accommodate the total flow of 1,700 gpm during peak loads and the piping must be insulated to minimize heat transfer to and
177 from the ground..... 26

178 Figure 16: Buildings connected to the ETP removing energy from the ETP while energy from the GHX modules is injected into
179 the pipe to maintain efficient operating temperatures. 28

180 Figure 17: Buildings connected to the ETP injecting energy to the ETP while energy from the GHX modules is extracted from
181 the pipe to maintain efficient operating temperatures. 28

182 Figure 18: With some building heating and others cooling, energy is simply transferred from one building to the next, reducing
183 the requirement for GHX modules..... 29

184 Figure 19: The addition of other heat sources and / or heat dissipation devices can reduce the size and cost of GHX modules
185 required for the system while improving long-term system performance. 30

186 Figure 20: Initial buildings can be retrofitted with a GSHP system without connecting to a large integrated district energy
187 sharing system. 30

188 Figure 21: An energy transfer pipe connects five buildings to enable the transfer of energy from one building to the next..... 31

189 Figure 22: Illustrates the development of 2 separate district energy modules connected with and energy transfer link to
190 transfer energy across the campus. 31

191 Figure 23: Campus buildings currently connected to the central energy plant with steam and chilled water piping in the utility /
192 pedestrian tunnels and buried piping. 34

193 Figure 24: First step for the BSU geothermal conversion project..... 34

194 Figure 25: Phase 1 ETP installation..... 35

195 Figure 26: Initial steps for Phase 2 of the district geothermal energy system with the installation of an HDD GHX for the PE
196 Complex..... 35

197 Figure 27: Phase 2 construction of the ETP connecting the Gillett Wellness Center with the PE Complex..... 36

198 Figure 28: Sattgast Hall and the AC Clark Library connected to the Phase 1 ETP as well as a vertical GHX and water well
199 heat exchanger. 37

200 Figure 29: Initial phases of the Phase 3 ETP construction..... 37

201 Figure 30: BSU geothermal district system roadmap..... 38

202 Figure 31: Wastewater heat recovery system integrated with vertical GHX..... 40

203 Figure 32: Integration of energy transfer pipe with irrigation lines for football fields, soccer pitches, and baseball diamonds. 41

204 Figure 33: Integration of energy transfer pipe with piping under sidewalks and parking lots for snow melt 41

205 Figure 34: On-site CO₂ emission reductions per building construction step..... 43

206 Figure 35: CO₂ reductions - buildings with efficiency measures. 44

207 Figure 36: OTPCO projected carbon intensity through 2022. 45

208 Figure 37: Annual cost of REC's to offset CO₂ emission from electricity consumption. 46

209

210 **List of Tables**

211

212 Table 1: Estimated capital and energy costs broken into recommended construction steps. 5

213 Table 2: Equipment installed in existing central energy plant..... 10

214 Table 3: Building breakdown by occupancy, total area, and space usage (SU). 10

215 Table 4: Monthly electricity and natural gas consumption with cost for 2019-2020. 11

216 Table 5: TC and TD calculated from water well lithology and depth. 15

217 Table 6: Building ranking based on current HVAC condition and years remodeled. 17

218 Table 7: Annual energy use broken into space heating and cooling energy. 18

219 Table 8: Building priority list with size and cost of incremental ground loop required to heat and cool each building with

220 efficiency measure upgrades. 20

221 Table 9: Building priority list with incremental land area and location required to heat and cool each building with efficiency

222 measure upgrades. 22

223 Table 10: Estimated capital, energy costs savings and economic calculations broken into recommended construction steps

224 with efficiency measure upgrades. 42

225

226

227

228

229

230

231

232

233

234

235

236

237

238

239

240

241

242

243

244

245

246

247

248

249

250

251

252

253

254

255

256

257

258

259

260

261

262

263

264

265 **List of Abbreviations**

266

267	AHU	Air handling unit
268	BAS	Building automation system
269	BSU	Bemidji State University
270	CHP	Combined heating and power
271	CO ₂	Carbon dioxide
272	COP	Coefficient of performance
273	EER	Energy efficiency ratio
274	ERV	Energy recovery ventilator
275	ETP	Energy transfer pipe
276	GHX	Ground heat exchanger
277	GLD	Ground loop design
278	GSHP	Ground source heat pump
279	HDD	Horizontal directionally drilled
280	HDPE	High density polyethylene
281	HVAC	Heating, ventilation, and air conditioning
282	LEED	Leadership in Energy and Environmental Design
283	MT	Metric ton
284	OTPCO	Otter Tail Power Company
285	REC	Renewable energy credit
286	TC	Thermal conductivity
287	TD	Thermal diffusivity

288

289

290

291

292

293
294
295
296
297
298
299
300
301
302
303
304
305
306
307

1. Introduction

BSU is a public state university located on the shores of Lake Bemidji and was founded in 1919 with the first class consisting of 38 students. Since then, BSU has grown to over 5,400 students with over 23 buildings on campus.

BSU has embarked on a plan to achieve carbon neutrality by 2050. The Sustainability Office on campus is devoted to sustainability efforts which is funded by a student ‘green fee’ of \$7.50 a semester. Among their many initiatives towards sustainable, green energy, BSU is considering the installation of a district GSHP system as a potential strategy to reduce on site emissions from fossil fuels and energy consumption.

Currently, the 23 buildings included in this analysis are cooled with 2 chillers and heated with 3 high pressure steam boilers (Table 2). Additionally, the campus uses 1 low pressure boiler in the summer for domestic hot water. Electricity is supplied by OTPCO and natural gas is supplied by Minnesota Energy Resource and Constellation Energy Company.

Table 2: Equipment installed in existing central energy plant.

		Year Installed	Capacity	Primary Use
Heating	Low-Pressure Hot Water	1990	---	Summer / DHW production
	High-Pressure Steam	1990	23,000 pounds / hour	Stage 1 heating
	High-Pressure Steam	1990	23,000 pounds / hour	Stage 2 heating
	High-Pressure Steam	2008	43,000 pounds / hour	Peak heating (Dec-Feb)
Cooling	Chiller 1	1997	500-Ton	Alternating years
	Chiller 2	2008	550-Ton	Alternating years

308
309
310
311
312
313
314
315

The building name, occupancy and space usage breakdown that can be seen in Table 3, is based on current data. Additional information was gathered during several phone interviews and video conferences with the building operators. This information was used to diagnose optimum construction steps and methodology that offer the best business investment value by minimizing capital cost while maximizing the reduction of operating costs and greenhouse gas emissions.

Table 3: Building breakdown by occupancy, total area, and space usage (SU).

Site Name	Occupancy	Current SF	SU 1	SU 1%	SU 2	SU 2%	SU 3	SU 3%	SU 4	SU 4 %
Deputy Hall	12 months	78,656	Office	95%	Computer Center	5%				
Bangsberg Hall	9 months	86,878	Educational Laboratory	55%	Classrooms	25%	Office	10%	Theater/Auditorium	10%
Bensen Hall	9 months	53,342	Classrooms	70%	Office	20%	Workshop	10%		
Hobson Memorial Union	9/Office 12	76,756	Dining	45%	Office	20%	Common Areas	16%	Workshop	10%
Central Maintenance Building	12 months	20,317	Workshop	60%	Warehouse	20%	Parking	15%	Office	5%
Chet Anderson Stadium		19,911	Sports Arena	100%						
Physical Education Complex	12 months	121,586	Gymnasium	31%	Fitness	21%	Workshop	15%	Locker Rooms	13%
Gillett Wellness Center	12 months	85,765	Gymnasium	38%	Fitness	26%	Locker Rooms	16%	Office	10%
Sattgast Hall	9 months	107,598	Educational Laboratory	45%	Classrooms	20%	Workshop	15%	Office	10%
AC Clark Library	9 months	71,462	Stacks and Reading	75%	Computer Center	25%				
Central Receiving	12 months	8,080	Maintenance/Repair	50%	Warehouse	45%	Office	5%		
American Indian Center	9 months	10,388	Office	33%	Theater/Auditorium	25%	Classrooms	15%	Workshop	10%
Bridgeman Hall	9 months	33,772	Educational Laboratory	50%	Classrooms	40%	Office	10%		
Decker Hall	12 months	29,424	Classrooms	55%	Educational Laboratory	45%				
Memorial Hall	9 months	53,893	Office	45%	Classrooms	25%	Computer Center	15%	Common Areas	15%
Walnut Hall	12 months	57,167	Dining	41%	Storage	25%	Office	19%	Kitchen	14%
Cedar Hall	9 months	39,133	Dorm Rooms	60%	Common Areas	34%	Dining	5%	Apartments	1%
Birch Hall	9 months	62,184	Dorm Rooms	60%	Common Areas	34%	Dining	5%	Apartments	1%
Linden Hall	9 months	67,565	Dorm Rooms	54%	Common Areas	31%	Workshop	10%	Dining	5%
Oak Hall	9 months	128,550	Dorm Rooms	51%	Common Areas	29%	Workshop	15%	Dining	4%
Tamarack Hall	9 months	88,410	Dorm Rooms	60%	Common Areas	34%	Dining	5%	Apartments	1%
Pine Hall	9 months	50,264	Dorm Rooms	60%	Common Areas	34%	Dining	5%	Apartments	1%
Hagg-Sauer Hall	9 months	82,478	Classrooms	55%	Theater/Auditorium	20%	Office	15%	Workshop	10%

316
317
318
319
320
321

2. Utility history

322 The electricity and natural gas bills were collected from OTPCO, Constellation, and Minnesota Energy Resources for 2019-
 323 2020. Table 4 shows the campus monthly natural gas consumption in therms, electricity consumption in kWh and respective
 324 costs. The campus operates on one main electricity meter and one main natural gas meter. Since electricity and natural gas
 325 is not sub-metered to any of the buildings, accurate information is unavailable for each of the buildings.
 326

327 Table 4: Monthly electricity and natural gas consumption with cost for 2019-2020.

Month	Gas Use (Therms)	Gas Cost (\$)	Electricity Use (kWh)	Electricity Cost (\$)
Jan	183,658	\$74,685	928,800	\$77,315
Feb	163,501	\$64,975	928,800	\$77,223
Mar	137,936	\$52,725	860,400	\$70,837
Apr	104,972	\$38,164	716,543	\$57,251
May	18,373	\$7,483	526,800	\$46,151
June	13,662	\$5,180	752,400	\$65,125
July	12,956	\$4,936	936,540	\$72,161
Aug	14,445	\$5,584	1,031,760	\$78,269
Sept	91,740	\$12,708	954,240	\$81,164
Oct	92,776	\$34,349	913,800	\$73,890
Nov	117,139	\$48,238	937,680	\$69,434
Dec	175,666	\$72,871	907,620	\$67,667
Total	1,126,823	\$421,898	10,395,383	\$836,486

328
 329
 330 The annual natural gas consumption is approximately 1,126,823 therms and 98% of the total natural gas consumption is
 331 estimated to be used for space heating. Therefore, space heating currently costs BSU \$413,460 annually and they currently
 332 pay, on average, \$0.39 / therm. Winter heating loads drive consumption from November through March with a peak usage
 333 shown in January at 183,658 therms. The total annual electricity use for 2019-2020 is 10,395,383 kWh costing BSU
 334 \$836,486. Electricity consumption is relatively constant year-round with a drop in usage from April-June due to summer
 335 break. This reduces the number of students and lighting in the buildings which in turn reduces space cooling and electricity
 336 usage. When classes begin in August, the electricity usage rises to its peak due to high occupancies from starting semester
 337 activities. The percentage of space cooling out of the total electricity usage is estimated at 20% based on similar values from
 338 previous projects. Therefore, currently BSU spends roughly \$167,297 annually on space cooling and pays \$0.081 / kWh. The
 339 current total campus heating and cooling cost is estimated at \$580,757.
 340

341 **2.1. Efficiencies**

342
 343 The primary benefit for using a steam boiler system is the amount of heat released as it condenses to water (986 Btu / lb). It
 344 is relatively safe, nontoxic and non-flammable. The disadvantages of using a steam district system are the heat losses in the
 345 distribution system that reduce efficiency by 15-20% according to Leadership in Energy and Environmental Design (LEED).
 346 Other heat losses on a steam boiler system can be attributed to steam traps, valve stems, blowdown, and flash losses. There
 347 is also reduced efficiency in the shoulder seasons when a high-capacity boiler is operating to meet a low heating requirement.
 348 To determine whether the natural gas usage in the system is normal relative to the climate, a regression analysis between
 349 monthly heating degree days and an average therms/day was performed and can be seen in Figure 1.




Figure 1: Regression between average monthly heating degree day/day and therms/day.

350
351

352 The coefficient of determination (R^2) is 0.92 which shows that the amount of natural gas consumed is consistent with the
 353 amount of heating required which therefore leads to confidence in the efficiency of the system. Although the amount of
 354 heating delivered is consistent with the amount of heating required, LEED recommends a minimum 15% reduction in
 355 efficiency from distribution losses. Since the boiler efficiency was determined as 88% after information gathering with the
 356 building operators at BSU, the total system efficiency for space heating is assumed to be 73%. For the space cooling, an
 357 estimated energy efficiency ratio (EER) of 10.2 for the chillers is used.

358

3. Methodology

359

3.1. Space heating and cooling block loads

360

361

362 To quantify the individual buildings space heating and cooling loads accurately with limited data, previously constructed
 363 building energy models (using Trane Trace 700 V6.3.4.0) from an energy model database using Bemidji weather data were
 364 used to extract monthly peak heating and cooling loads and monthly heating and cooling energy loads for the space usages
 365 seen in Table 3.
 366

367

368 The existing energy models incorporated ASHRAE 90.1 (2013) building envelope u-factor standards for the roof, walls, and
 369 windows. The energy loads from the existing energy models were scaled to match the floor area of each building. For
 370 example, the Bangsburg Fine Arts Complex is an 87,778 ft² building comprised of 55% educational laboratory (48,278 ft²),
 371 25% classrooms (21,945 ft²), 10% office space (8,778 ft²), and 10% theatre space (8,778 ft²). The existing energy model
 372 hourly load sets used were scaled and aggregated accordingly to match the square footage per space usage for the
 373 Bangsburg Fine Arts Complex represented in Figure 2. This method for obtaining hourly heating and cooling loads was
 374 replicated for the 23 buildings in this analysis. The aggregated energy loads for all the buildings on campus were calibrated to
 375 within 7% of the annual energy bills from BSU.




Figure 2: Monthly peak and total cooling and heating load based on hourly calculations for the Bangsburg Fine Arts Complex.

376
377

378

379 3.2. Energy efficiency measures

380

381 Several iterations of the energy models were created and used for the analysis described in Section 3.1. In addition to the
 382 standard ASHRAE 90.1 energy model outputs, two efficiency measures were applied to manipulate and ultimately reduce the
 383 heating and cooling loads. The first efficiency measure that was applied was an exhaust air energy recovery ventilation
 384 system (ERV). This efficiency measure was applied to buildings without an existing ERV. ERV's use exhaust air to pre-heat
 385 or pre-cool incoming outdoor ventilation air as seen in Figure 3 and can have substantial savings on energy usage and costs.
 386




Figure 3: Energy recovery ventilation system

387
388

389

390 ERV's reduce the peak and annual heating load in a colder climate like Bemidji. When an ERV was applied to the Bangsburg
 391 Fine Arts Complex, the peak cooling and heating loads reduced by approximately 10% and 36%, respectively, compared to
 392 the standard building model (Figure 4). Similarly, the annual heating energy load was reduced by 24%. An ERV was applied
 393 to every building included in the analysis and they not only increase the energy savings, but significantly reduce the GHX size
 394 required due to the increase in balance between heating and cooling loads.
 395




Figure 4: Bangsburg Fine Arts Complex energy profile with ERV.

396
397

398 The second efficiency measure applied in this analysis was upgraded lighting. This efficiency measure was applied to
 399 buildings without a recent lighting upgrade. The lighting intensity in a building is typically measured in W/ft² and the lower the
 400 lighting intensity, the lower the cooling load. Lighting intensity can be reduced by installing LED lights, occupancy sensors and
 401 daylight sensors. Daylight sensors measure ambient light levels and adjust lighting levels when outdoor ambient light is
 402 sufficient. This takes into consideration seasonal changes in the day/night cycle.
 403

404 For this analysis, an assumed lighting intensity of 1.2 W/ft² was used for buildings without recent lighting upgrades and 0.6
 405 W/ft² for a hypothetical retrofit or an existing building on campus that recently underwent a retrofit such as Deputy, Walnut
 406 and Sattgast Halls, the A.C. Library and the Gillette Wellness Center. Although, lighting upgrades can have a large impact on
 407 cost savings, the total energy reduction for both heating and cooling is typically low. The greater impact is seen in the impact
 408 on the energy balance, with a reduction in cooling load and a corresponding increase in heating loads. For example, the
 409 Bangsburg Fine Arts Complex, a decrease in lighting intensity from 1.2 to 0.6 W/ft², the peaking cooling load was reduced by
 410 8% and peak heating load increased by 7% (Figure 5). Annual cooling loads decreased by 10% while annual heating loads
 411 increased by 15%.
 412
 413





Figure 5: Bangsburg Fine Arts Complex energy profile with lighting upgrades.

414
415

416 When combining an ERV and lighting upgrades, this allows for an amplified effect on the decrease of energy savings and
 417 GHX size. As seen in Figure 6, the peak cooling load reduces by 18%, the peak heating load reduces by 38%, the annual
 418 cooling load decreases by 11% and the annual heating load decreases by 14%. For each individual building, the reductions
 419 appear respectable, but when the efficiency measures are applied to a district system, the reductions are compounded and
 420 substantial.

421



422
423

Figure 6: Bangsburg Fine Arts Complex energy profile with ERV and lighting upgrades.

424

3.3. GLD numerical modelling

425

426

427

428

429

430

To determine the size of the GHX required for the space heating and cooling loads developed in Section 3, GLD (V10.0.43) software was used to calculate the size and performance of the GHX by calculating long-term ground temperature trends and heat pump entering water temperatures. GLD is used to calculate the size, configuration, and long-term performance of several different types of GHX. For this analysis we analysed vertical and HDD configurations.

431

432

Initially, a vertical GHX was designed due to the construction familiarity for local contractors. For a vertical GHX, the following inputs are required.

433

434

435

- The local thermal conductivity (TC),
- Thermal diffusivity (TD) and
- Ambient ground temperature

436

437

438

439

To estimate the TC and TD, soil stratigraphy information was gathered from water well logs in the Minnesota Well Index (<https://mnwellindex.web.health.state.mn.us/>). Data from a well drilled on the BSU campus was found and the stratigraphy with estimated TC and TD can be seen in Table 5. Along with the TC and TD, the undisturbed ground temperature was estimated at 49°F based on the average annual air temperature for the location. Other required inputs include:

440

441

442

- Pipe size and type,
- Borehole diameter,
- Thermal conductivity of grout installed between the GHX pipe and soil, can be seen in Figure 7.

443

444


445

446

Based on the geology found in the Bemidji area, horizontal directionally drilled GHX's can typically be installed at a cost between 10% and 15% less than a vertical GHX of similar capacity.

Table 5: TC and TD calculated from water well lithology and depth.

Depth		Layer	Lithology	Weighted TC	Weighted TD
Start	End			Avg	Avg
0	30	30	Sand 80 lb 10%	0.11	0.06
30	32	2	Clay 100 lb 10%	0.00	0.00
32	88	56	Sand 100 lb 20%	0.36	0.21
88	103	15	Sand 120 lb 15%	0.12	0.07
103	154	51	Clay 100 lb 20%	0.15	0.10
154	156	2	Sand 100 lb 15%	0.01	0.01
156	228	72	Clay 120 lb 15%	0.28	0.16
228	241	13	Sand 120 lb 15%	0.10	0.06
Depth	241			1.14	0.67




447
448 Figure 7: Typical vertical ground heat exchanger pipe parameters along with solution properties and design system flow rate.

449
450 There are several advantages of an HDD GHX. These include:

- 451 • Lower capital costs,
- 452 • Minimal site disturbance, (horizontal boreholes can be installed under existing paved parking areas)
- 453 • The proximity of the horizontal GHX piping to the atmosphere allows dissipation of excess heat to the atmosphere in
- 454 winter and warm outdoor air temperatures and rainfall can add energy to the GHX during the summer, eliminating
- 455 the potential for long-term temperature degradation

456 Similar to the vertical GHX methodology, the same well log was used to calculate the TC and TD but to a shallower depth of
457 32 ft which yielded a TC of 0.83 Btu/h-ft-°F and TD of 0.46 ft²/day. Because of the impact of outdoor air temperatures on the
458 shallow boreholes, the regional air temperature swing and coldest/warmest day of the year is needed. In Bemidji, the regional
459 air temperature swing is 33°F and the coldest/warmest day of the year is February 4th and August 5th, respectively. The piping
460 configuration was modelled as 3 sets of u-tubes stacked vertically to a depth of 30 ft, 20 ft, and 10 ft. 1 1/4" SDR 11 pipe was
461 used for the u-tubes. A visual representation can be seen in Figure 8. These sets of U-tubes are installed adjacent to each
462 other in rows with a separation of 10 ft.
463



464
465 Figure 8: Visual representation of horizontal directionally drilled boreholes.

3.4. Building order selection

466
467
468 The campus consists of 23 existing buildings built between 1919 and 2009. Some of the buildings have had renovations as
469 recently as 2016 while others have had few renovations since 1966. To minimize capital cost expenditures, it is more cost-
470 effective to consider the installation of a geothermal heat pump system at a time the existing equipment is scheduled for
471 replacement rather than replacing equipment before end of life.
472

473 A building retrofit order was determined based on building type, location, and the heating, ventilation, and air conditioning
 474 (HVAC) condition ranking seen in Table 6. Additional information was provided by the University indicating the residence
 475 buildings should be converted last due to the availability of capital funds which adjusted the building order selection.
 476
 477

Table 6: Building ranking based on current HVAC condition and years remodeled.

Building	Year Completed	Remodel	Remodel	Remodel	Remodel	HVAC condition (10 = new; 0 = replacement necessary)
Bangsberg Fine Arts Complex	1971					1
Deputy Hall	1919	1928	1949	1979	1981	1
Chet Anderson Stadium	1938	1989				1
Bensen Hall	1950	1986				2
Physical Education Complex	1959	1967				2
Hobson Memorial Union	1967	1972				3
Walnut Hall Food Service	1969	1991				3
Cedar Hall	1959	1991				4
Heating Plant & Garage	1926	2020				5
Gillett Wellness Center	1989					6
Sattgast Hall (original)	1962	1989				6
A.C. Clark Library	1966	1999				7
Central Receiving	1979					7
American Indian Resource Center	2001	2009				8
Birch Hall	1952					8
Bridgeman Hall	1964	2004	2006			8
Linden Hall	1959	1964	2007			8
Oak Hall	1965	1966				8
Tamarack Hall	1969	2010				8
Decker Hall	1957	1964	1979			9
Memorial Hall	1940	2016				9
Sattgast Hall (south addition)	2009					9

478
 479

3.5. Energy reduction calculations

480
 481
 482
 483
 484
 485
 486

To quantify the projected reduction in CO₂ emissions and operating costs, the existing energy consumption seen in Table 4 was used as the baseline. Based on conversations with the building operators, the percentage of space heating from natural gas usage is 98% with a heating system efficiency of 73%. For the space cooling, the percentage of electricity consumption was estimated at 25% with a coefficient of performance (COPc) of 3 (EER of 10.2) for the chillers.

487 Based on the percentages and efficiencies, a current district space cooling load of 26,638,169 kBtu and heating load of
 488 80,612,882 kBtu was determined (Table 7). Using the energy models discussed in Section 3.1 and the current district space
 489 cooling and heating load, the aggregated modelled energy loads were calibrated to match the current district loads within 5%.
 490

491 Once the individual building energy loads were established, the energy savings were calculated based on the difference in
 492 efficiencies. With a GSHP, the heating COP was determined at 4.5 based on a 40°F source side temperature and a 110°F
 493 load side temperature. For cooling, a COPc of 5.1 (EER of 17.4) was determined based on an 80°F source side temperature
 494 and a 45°F load side temperature. The resulting energy cost savings and CO₂ emissions reduction is discussed more
 495 thoroughly in Sections 7 and 8.
 496

497 Table 7: Annual energy use broken into space heating and cooling energy.

Heating		Annual Use (Therms)	Annual kBtu Heating Load	Annual Heating kBtu Delivered
Campus Gas Consumption		1,126,823		
% Gas Used for Space Heating	98%	1,104,286	110,428,605	
Central Boiler Efficiency (%)	73%	806,129		80,612,882
Cooling		Annual Use (kWh)	Annual kBtu Cooling Load	Annual Cooling kBtu Delivered
Campus Electricity Consumption				
% Electricity used for Space Cooling	25%		8,867,262	
Central Chiller Efficiency (EER)	10.25			26,638,169

498
499
500
501
502
503
504
505

For the energy savings from an ERV, the heating energy consumption was reduced by 39.6% based on the energy model estimates and the cooling energy consumption was increased by 5.9%. To determine the energy savings from the lighting upgrades, a reduction in lighting intensity from 1.2 to 0.6 W/ft² was assumed. Based on the floor area of each building applied with the lighting upgrades and an average annual lighting operating hours of 4271, the energy savings were determined. The annual lighting operating hours was determined from a lighting audit conducted on a similar type college campus.

506 4. GSHP system integration

507
508
509
510
511

A GSHP system is comprised of three components:

- Distribution system
- Heating and cooling equipment
- The GHX

512 4.1. Distribution system

513
514
515
516
517
518
519

In the existing BSU campus buildings, the distribution system and ductwork that distributes heating and cooling throughout the buildings are already in place. Air handling units (AHU's) currently provide heating with steam boilers connected to steam converters and cooling with electric chillers. Implementing a GSHP system into each building will most likely require the upgrade of the existing AHU's hot and chilled water coils. Water to water heat pumps will be required to supply hot and chilled water to the coils. These heat pumps will not replace the boilers and chillers in the central plant but will need to be located in the buildings that they serve.

520
521
522
523

As buildings are connected to the GSHP system, the capacity of the boilers and chillers in the existing central energy plant can potentially be reduced.

524
525
526

Additionally, the load side entering water temperature has a large impact on the energy savings and efficiency of the system. For example, when designing the entering heating water for the AHU's for 130°F versus 110°F, this not only reduces the efficiency of the system by 25%, but also decreases the size of the GHX by approximately 10%.

527
528
529
530

For new buildings, water to water heat pumps offer more flexibility in designing distribution systems as they are not tied to the temperatures supplied by the central plant. Low temperature heating and high-temperature cooling systems can be considered such as a radiant floor system that heats with 85-90°F water and cools with 65°F chilled water.

531
532
533
534
535

It is critical to design the system in the most efficient manner to maximize the capital and operating cost savings. The capital cost for the replacement of heating and cooling coils are not considered in this study due to the anticipated end of life retrofit. Although the cost of coils was not considered, the cost of coils designed for 110°F water is not significantly greater than the cost of coils requiring 130°F water.

536
537

537 4.1.1. Exhaust air energy recovery

538

539 Recovering energy from air exhausted from the building provides significant reductions in kWh consumption and kW demand
540 regardless of whether a GSHP system is installed or not as shown in Section 3.2. The cost of installing an ERV is typically
541 around \$2 / ft² of building. Installing an ERV system requires the installation of ductwork between the location of exhaust fans
542 and the appropriate ERV equipment installed with each AHU. They can also be integrated with an existing system
543 inexpensively by using less intrusive design methods.
544

545

546 The cost of heat pump equipment and the GHX required for a GSHP system is directly related to the energy loads of the
547 building. Since energy loads are reduced as other energy efficiency measures are implemented in the facility, the reduced
548 cost of a GSHP system helps offset the cost installing an ERV. Additionally, in some cases, an ERV can reduce the capacity
549 needed for the heat pump equipment.

550

4.2. Heating and cooling equipment

551

552 The implementation of a GSHP system will require mechanical room space to house water to water heat pump equipment,
553 circulation pumps and GHX supply/return pipes. Hot and chilled water piping will be required from the mechanical room space
554 to the existing AHU's. To accommodate the heat pump equipment, circulation pumps and other mechanical equipment, an
555 external modular mechanical room seen in Figure 9 is an option that can be considered for buildings with inadequate space
556 for an internal mechanical room .
557

558

559 Installing high efficiency heat pumps versus a low efficiency heat pump can decrease the ground loop size by 5% and for
560 cooling dominant buildings up to 10%. Additionally, high efficiency heat pumps will allow for greater energy savings and
561 reduced CO₂ emissions. The main difference between a high and low efficiency heat pump is the EER and COP. The EER is
562 the ratio output of cooling energy delivered to input electrical energy to run the heat pump whereas the COP is the same ratio
563 for heating. A high efficiency heat pump typically has an EER of 20 and COP of 4.7 whereas a low efficiency heat pump has
564 an EER of 12 and COP of 3.7. The higher the EER and COP, the more cost savings, and less CO₂ emissions.

565



566

567 *Figure 9: External modular mechanical room to house water to water heat pumps, and circulation pumps can possibly be located near the campus buildings.*

568

4.3. GHX

569

570 One of the main components of a GSHP system is the GHX. It consists of plastic pipe buried in the ground adjacent to a
571 building. The total campus footprint is approximately 160 acres. Within the campus footprint, there is available space for a
572 HDD GHX under the Bangsburg parking lot, Chet Anderson Stadium field, soccer complex, PE parking lot, BSU athletic field,
573 Maple parking lot, Birch parking lot and Tamarack parking lot. Based on the methodology discussed in Section 3.4, the HDD
574 GHX has been designed to be a step-by-step type installation based on building priority.
575

575

576 Rather than retrofitting the entire campus simultaneously which would require large amounts of capital, Table 8 shows the
 577 order of buildings to be retrofitted when funds are available. Since the land area is limited, it was determined that the scenario
 578 without installing efficiency measures would not be feasible. If efficiency measures are not installed, the GHX size increases
 579 by an average of 40%. All GHX installations will be HDD except for steps I where a vertical GHX will be installed. Also, steps
 580 J and O will utilize a water well heat exchanger. The total campus GHX length is estimated at 387,345 ft and will cost
 581 approximately \$4,808,140, when efficiency measures are added to each building.
 582
 583

Table 8: Building priority list with size and cost of incremental ground loop required to heat and cool each building with efficiency measure upgrades.

	Building Priority List	Incremental GHX Length (ft)	Estimated Installation Cost
A	Deputy Hall	36,729	\$440,748
B	Bangsburg Hall	10,313	\$123,756
C	Bensen Hall	8,349	\$100,188
D	Hobson Memorial Union	19,054	\$228,648
E	Heating Plant	1,932	\$23,184
F	Chet Anderson Stadium	0	\$0
G	PE complex	61,383	\$736,596
H	Gillett Wellness Center	48,090	\$577,080
I	Sattgast Hall	26,040	\$312,480
J	AC Clark Library	Water Well System	\$30,000
K	Central Receiving	3,885	\$46,620
L	American Indian Resource Center	6,615	\$79,380
M	Bridgeman Hall	7,035	\$84,420
N	Decker Hall	7,875	\$94,500
O	Memorial Hall	Water Well System	\$130,000
P	Walnut Hall	12,810	\$153,720
Q	Cedar Hall	10,395	\$124,740
R	Birch Hall	16,380	\$196,560
S	Linden Hall	17,850	\$214,200
T	Oak Hall	33,915	\$406,980
U	Tamarack Hall	23,205	\$278,460
V	Pine Hall	13,335	\$160,020
W	Hagg-Sauer Hall	22,155	\$265,860

584
 585
 586
 587 HDD GHX's are a non intrusive type of drilling with only a 5'x 5' trench adjacent to the drill rig required as seen in Figure 8.
 588 Although the HDD GHX is fairly unintrusive, available land area is still required for the pipe to be buried under. Based on the
 589 various lengths of GHX in Table 8, six key drilling areas have been identified as Bangsburg parking lot, Chet Anderson
 590 Stadium field, soccer complex, PE parking lot, BSU athletic field, Maple parking lot, Birch parking lot and Tamarack parking
 591 lot as seen in Figure 10. The total aggregated land area required for the GSHP retrofit with efficiency measures is 1,254,410
 592 ft². Note that the capital costs associated with each GHX, include the connections to the energy transfer pipe (ETP) from the
 593 GHX. This is shown in a detailed breakdown for location and per building in Table 9.

594



595
596

Figure 10: Key drilling sites for the HDD GHX

597

598

Table 9: Building priority list with incremental land area and location required to heat and cool each building with efficiency measure upgrades.

	Building Priority List	Incremental Land Area (ft2)	Location
A	Deputy Hall	116,400	Bangsburg Parking Lot
B	Bangsburg Hall	5,400	Bangsburg Parking Lot
C	Bensen Hall	39,700	Bangsburg Parking Lot
D	Hobson Memorial Union	86,510	Chet Anderson Stadium
E	Heating Plant	6,580	Chet Anderson Stadium
F	Chet Anderson Stadium	0	Chet Anderson Stadium
G	PE complex	204,750	Soccer Complex
H	Gillett Wellness Center	160,020	Soccer Complex
I	Sattgast Hall	50,000	Adjacent to Sattgast Hall
J	AC Clark Library	100	Adjacent to A.C. Library
K	Central Receiving	13,090	BSU Athletic Field
L	American Indian Resource Center	22,135	Chet Anderson Stadium
M	Bridgeman Hall	23,400	Maple Parking Lot
N	Decker Hall	26,075	Soccer Complex
O	Memorial Hall	100	Adjacent to Memorial Hall
P	Walnut Hall	42,630	Maple Parking Lot
Q	Cedar Hall	34,580	Maple Parking Lot
R	Birch Hall	54,600	Birch/Linden Hall Parking Lot
S	Linden Hall	59,570	Tamarack Parking Lot
T	Oak Hall	112,805	BSU Athletic Field
U	Tamarack Hall	77,560	BSU Athletic Field
V	Pine Hall	44,275	BSU Athletic Field
W	Hagg-Sauer Hall	74,130	BSU Athletic Field

599
600

601

4.3.1. Water wells

602

603

Groundwater can provide a constant energy source / heat sink when it is available. BSU is on the shore of Lake Bemidji and groundwater moves readily through the spaces between particles of sand and gravel beneath the ground. Groundwater in this area is at a constant temperature of approximately 47°F.

605

606

607

When the fluid temperature in the ETP is above or below the groundwater temperature, energy can be transferred to or from the system. Groundwater can be circulated through a heat exchanger connected to the ETP similar to the connections of the solar thermal and snowmelt seen in Figure 19.

609

610

611


Groundwater can be drawn from a supply well, circulated through a heat exchanger connected to the ETP and returned to the ground via a return well. Alternatively, a heat exchanger can be installed directly in a water well. Inducing flow across the heat exchanger by drawing water from a water bearing zone at one depth and returning it into a water bearing zone at a different level above a heat exchanger installed inside the water well. Fluid from the ETP is circulated through the heat exchanger in the well, transferring energy to or from the system¹. Installing the heat exchanger within the well casing allows the transfer of energy between the ETP and the aquifer without physically removing water from the ground, reducing the risk of contamination.

616

617

618

¹ DARC Systems is a firm located in Minneapolis that manufactures the heat exchangers designed for installation in the well casing.



619
620
621

Figure 11: Transferring energy between the ETP and an aquifer can be accomplished with supply / return well pair and a heat exchanger in a mechanical room or with the installation of a heat exchanger located in the well casing.

622

4.3.2. Surface water heat exchanger

623

624

625

626

627

628

629

630

631

Surface water heat pump systems could be an alternative or additive technology to support the HDD GHX system. They utilize surface water bodies such as lakes, reservoirs, and rivers as heat sources and heat sinks. Closed-loop surface water heat pumps use submerged heat exchangers to extract or reject heat from the surface water body. Heat transfer between the heat exchanger and the lake is typically due to natural convection. Since the BSU campus is on the shore of Lake Bemidji, this allows for the opportunity of utilizing a surface water heat exchanger in Lake Bemidji to control the temperature of the energy transfer pipe.

632

633

634

For a surface water heat pump system, the heat exchanger coils are often made of high-density polyethylene (HDPE) pipes, but some projects use titanium alloy or galvanized steel tube heat exchangers which can have a higher cost and corrosion problems. There are two main configurations of surface water heat exchangers:

635

636


- HDPE slinky type (Figure 12)
- Stainless steel plate (Figure 13)



637
638

Figure 12: HDPE slinky surface water heat exchanger being sunk to the bottom of a pond.

639
640



641
642

Figure 13: Stainless steel plate surface water heat exchanger.

643
644
645
646
647
648

Depending on the location and occupancy of the BSU campus shoreline on Lake Bemidji, the installation would need to be coordinated to minimize risk of propeller contact from recreational boats. This could ultimately cause a system failure from a broken pipeline. If installed properly, this technology has the potential to not only reduce the capital costs from the reduced size of the GHX field, but also reduce the annual operating costs and CO₂ emissions due to increased efficiencies.

649
650

5. District system configuration


651 A traditional district system consists of a central energy plant that produces steam or hot water and / or chilled water that is
 652 delivered to the buildings connected to the system. Conventional systems burn fossil fuels (gas, oil, propane, or coal) and
 653 deliver hot water at approximately 160°F or greater, or steam. Chilled water is produced with conventional water-cooled
 654 chillers. GSHP systems can and have been used in place of conventional fossil fuel boilers and water-cooled chillers.
 655

656 An alternative approach that works well with a GSHP system is often referred to as an “energy sharing system”. An
 657 energy transfer pipe (ETP) moves energy around a single continuous pipe loop. Buildings connected to the ETP add energy
 658 to it when they are being cooled and remove energy from it when they are being heated, much like parcels added to or
 659 removed from a conveyor belt.
 660

661 The two district system design approaches are described in the following sections.
 662

663 5.1. Central energy plants

664 A traditional district heating system is based on a large central heating / cooling plant that produces hot and / or chilled water
 665 that is distributed to buildings connected to it. The schematic design of a central plant district heating / cooling system is
 666 illustrated in Figure 14. The capacity of the central plant and the hot and chilled water distribution system must be designed to
 667 meet the peak heating and cooling loads of all buildings that will potentially be connected to it.
 668
 669



670
 671 Figure 14: With a central energy plant all boreholes are connected to the heat pump in the central plant.

672 5.1.1. GHX connections to central energy plant

673 Energy is transferred to or from the GHX at a single, central location, at the large heat pump in the central energy plant. All
 674 boreholes are connected to the central energy plant and, depending on the land area available near the central plant building,
 675 may significantly increase the cost of connecting the GHX to the system and can have an impact on construction cost.
 676
 677


678 5.1.2. Distribution piping

679 When all heating and cooling is distributed from a central energy plant, the hot and chilled water distribution system is sized to
 680 meet the peak heating or cooling capacity of the entire system. The flow rates shown for the buildings seen in Figure 16
 681 indicate a flow rate of 1,700 gpm at peak heating load for the buildings. With numerous connections to GHX modules to the
 682 single ETP shown in Figure 16, the peak flow rate required is reduced to 300 gpm. This flow rate can be accommodated with
 683 an ETP 8" in diameter.
 684
 685

686 To meet the peak system heating load from the central energy plant, the pipe must deliver 1,700 gpm to the buildings. This
 687 will require a pipe approximately 12-14" diameter to supply heated fluid to the building and a similar size pipe to return water
 688 to the central energy plant. In comparison, the single ETP requires a peak flow rate of 300 gpm that can be accommodated
 689 with a single 8" diameter pipe.

690
 691 To achieve the peak flow rate of 1,700 gpm used in this example, a 15 hp pump will be required. In comparison, a 2 hp pump
 692 will be required to achieve the peak flow rate of 300 gpm. This will have an impact on both capital cost as well as long term
 693 energy cost.

694
 695 In a system with a central energy plant heating water is delivered to the buildings at approximately 120°F and chilled water is
 696 delivered at approximately 45°F. Hot water piping buried in the 47°F ground will require insulation to prevent heat loss and
 697 will have to be insulated. Hot and chilled water piping that can be located in the utility tunnels will have to be insulated to
 698 prevent heat loss to the space and avoid condensation on the chilled water piping. In contrast, the water temperature
 699 delivered to the buildings connected to the single ETP can range between 35°F and 85°F without minimal impact on the
 700 heating and cooling delivered to the building. Insulation is not required for the buried portions of the single ETP.
 701



702
 703 *Figure 15: Hot and chilled water is delivered to all connected buildings. The pumps and piping system is designed to accommodate the total flow of 1,700*
 704 *gpm during peak loads and the piping must be insulated to minimize heat transfer to and from the ground.*

705

706 5.2. Energy sharing system

707

708 Buildings and GHX modules are connected to a single continuous pipe loop, or ETP. Water (or water mixed with antifreeze) is
 709 circulated around the ETP. Buildings connected to it add energy to the fluid in the ETP when the building is cooled, raising the
 710 temperature a few degrees, and remove energy from it when heating, lowering the temperature a few degrees.
 711

712 When a building adds heat to the ETP and the building adjacent to it removes the same amount, the temperature of the fluid
 713 in the pipe after the second building is the same as the fluid temperature before the first building. Energy transfer between
 714 buildings recaptures and recycles heat that would otherwise be dissipated through cooling towers and reduces or eliminates
 715 the need for burning fossil fuels to heat the buildings.
 716

717 When more heat is removed from the pipe than is being added, the temperature in the ETP drops. To continue operating
 718 efficiently, heat must be added to the pipe. GHX modules connected to the ETP at regular intervals along the length of the
 719 pipe add heat when the temperature of the fluid drops too low by activating the GHX circulation pump. Some of the cold fluid
 720 from the pipe is diverted to the GHX module, extracts heat from the ground and is injected back to the ETP.

721

722 Conversely, when the heat added to the pipe increases the temperature in the pipe, the GHX modules are activated to
723 dissipate heat to the ground. Typically, the temperature of the fluid in the pipe is maintained between 40° and 85°F. GHX
724 modules are activated as the temperature of the fluid falls outside of that range.

725

726 The GHX modules store excess energy when it cannot be used in other buildings connected to the ETP and release the heat
727 to the pipe when it is not available from other buildings.

728

729 The fluid temperature in the ETP operates at moderate temperatures, generally within 20-30°F of the ambient ground
730 temperature (about 47°F in Bemidji). Insulation is not required on the pipe, and the temperature is well within the temperature
731 parameters of HDPE pipe.

732

733 The size of the ETP is dictated by three factors:

734

- The flow required to meet the peak heating and cooling loads of the buildings connected to the ETP

735

- The temperature of the fluid circulating through the ETP

736

- The relative location of connections to buildings with connections to GHX modules

737

738 Figure 16 shows building connections to the ETP alternating with connections to GHX modules. Alternating connections of
739 GHX modules and building(s) to the ETP allows reductions in both capital cost and long-term operating costs of the system.

740

741 Figure 16 shows 13 buildings connected to an ETP. The building connections are labeled with numbers 1 to 13. GHX module
742 connections are found at regular intervals around the ETP after every 2nd or 3rd building. The GHX connections are labelled
743 from A to F. A pump, labelled the energy transfer pump, circulates fluid continuously around the ETP. The buildings in Figure
744 16 are shown in red, indicating they require heating. Circulation pumps in each building are drawing fluid from the pipe,
745 circulating the fluid through heat pumps in the buildings and injecting the fluid back into the ETP a few degrees cooler. In one
746 section of the pipe (building connections 10-13) each building lowers the temperature a few degrees.

747

748 GHX-A is immediately downstream of Building-13. If the temperature at A is lower than desired, the pump on the GHX
749 module is activated to divert some of the fluid through the GHX where it is warmed by the earth. The warmed fluid is pumped
750 downstream to Buildings-1 and 2 and heat is again removed from the fluid. Immediately after Building-2, the fluid is diverted
751 through GHX-B and re-warmed before it is pumped to Building-3. This process, with the fluid being cooled in the buildings
752 and warmed at intervals around the ETP, is repeated continuously as fluid is circulated through the ETP.

753

754 When all buildings are being cooled in summer, the opposite occurs. As heat is rejected to the ETP, efficient operating
755 temperatures are maintained by activating GHX pumps at intervals around the ETP, as shown in Figure 17.

756

756 5.2.1. System flow rates

757

758 Heat pumps require specific flow rates within specific temperature parameters to operate efficiently. Most heat pump
759 manufacturers recommend:

760

- Flow of 2.5 to 3.0 gpm per ton of capacity

761

- Minimum temperature of 30-35°F to maximum of 80°F entering water temperature when heating

762

- Minimum temperature of 50°F to maximum of 90-100°F entering water temperature when cooling

763

764 The flow needed through the ETP must meet the flow requirements of the largest building peak load connected to it. For
765 example (in Figure 16), if the peak heating load in Building-7 is 100 tons, the flow through the ETP must be approximately
766 300 gpm to deliver the required energy at a minimum temperature of 30-35°F.


767

768 To achieve this, the Energy Transfer Pump must circulate 300 gpm of fluid to the Building-7 connection. If the temperature of
769 the fluid is less than the minimum temperature required, the pump for GHX-D is activated to add heat to the pipe. Fluid
770 reinjected to the ETP at Building-7 is cooled as heat is removed by the heat pumps in the building, to be re-warmed before
771 the Building-8 connection by diverting the flow through the ETP through GHX-E.

771


772 Note that the flow required through each building (or group of buildings) totals 300 gpm or less, and that the fluid can be
773 diverted through a GHX module to collect energy from the earth to stay within the operating parameters of the heat pumps

774 connected to it. Because of the GHX connections to the ETP at regular intervals around the ETP loop, the temperature of the fluid
 775 can be maintained, while allowing a flow rate of 300 gpm to supply the energy required by heat pumps which traditionally
 776 would require a total flow of 1,700 gpm. This significantly reduces pumping energy required in the system and allows a much
 777 smaller pipe to deliver energy to heat pumps in the buildings.
 778



779
 780 Figure 16: Buildings connected to the ETP removing energy from the ETP while energy from the GHX modules is injected into the pipe to maintain
 781 efficient operating temperatures.

782 The system operates in the same way when all the buildings in the system are cooling, with heat being rejected to the ground,
 783 as seen in Figure 17.
 784




785
 786 Figure 17: Buildings connected to the ETP injecting energy to the ETP while energy from the GHX modules is extracted from the pipe to maintain
 787 efficient operating temperatures.

788 Much of the year, however, the scenario seen in Figure 18 is more likely, with some of the buildings requiring more heating
 789 than cooling while others require more cooling. Building-1 in Figure 18 extracts heat from the pipe, while Building-2 rejects
 790 heat to it. The temperature of the fluid drops after Building-1, increases at Building-2, resulting in minimal temperature
 791 change. Energy does not have to be added or removed to the pipe at GHX-B to maintain efficient operating temperature for
 792 Buildings 3, 4 and 6.

793
794
795
796
797
798
799

Depending on the temperature decrease after Buildings 3, 4 and 6, GHX-C and / or GHX-D may be needed to add energy to the pipe from the ground. After Building-7 adds energy to the ETP, heat is rejected to GHX-E. Three of the GHX modules are not required in the scenario seen in Figure 18. The temperature in the pipe is maintained within the desired operating range by heat added to or removed from it by the buildings themselves. This allows a reduction in the size and cost of the GHX modules required and reduces pumping energy required to operate the system.



800
801
802

Figure 18: With some building heating and others cooling, energy is simply transferred from one building to the next, reducing the requirement for GHX modules

803

5.2.2. Addition of discretionary heating and cooling loads

804

805

GHX modules are the backbone of the energy resource for a district geothermal energy system primarily because of the energy storage capability of the earth. A range of other energy resources can be connected to the ETP. Resources that can be connected to the system can include:

808

- Fluid cooler to dissipate excess heat from the system
- Snow melt system on sidewalks, roadways
- Sport field irrigation systems
- Water wells
- Waste heat from combined heat and power systems
- Waste heat from data center
- Solar thermal energy
- Wastewater energy transfer
- Waste heat from refrigeration system (ice rinks, grocery stores)

809

810

811

812

813

814

815

816

817

Connecting waste energy resources, renewable energy sources, or heat dissipation devices to the ETP to operate in conjunction or in parallel with GHX modules connected to the system can reduce the size and / or cost of the GHX modules required on the system by balancing the amount of energy transferred to and from the GHX on an annual basis. Balancing energy loads to and from the ground avoid long-term temperature increase or decrease in the GHX and help maintain system efficiency over the long term. Figure 19 illustrates a snow melt system connected to the ETP between Building-3 and GHX-B which dissipates excess heat from the system. A combined heat and power system that can add waste heat to the system can also be added if required.

822

823




Figure 19: The addition of other heat sources and / or heat dissipation devices can reduce the size and cost of GHX modules required for the system while improving long-term system performance.

824
825
826

5.2.3. Expanding the energy sharing system

827
828
829
830
831
832
833
834
835
836
837
838

The installation of a district geothermal heat pump system for BSU is anticipated to take place over the next 20-30 years. Building mechanical and electrical systems as well as the building envelop components are typically replaced at the end their anticipated life to avoid replacing serviceable equipment prematurely. During the first few years it is expected that one or two buildings will be retrofitted with a GSHP system.

To minimize the initial cost of retrofitting a district energy sharing system on the campus the first buildings that are converted can be designed as free-standing GSHP systems, avoiding the cost of the ETP, controls and additional infrastructure (if desired). Figure 20 illustrates 2 of the 13 buildings retrofitted with a GSHP system, each with a GHX designed to meet its heating and cooling loads.





Figure 20: Initial buildings can be retrofitted with a GSHP system without connecting to a large integrated district energy sharing system.

839
840

As more buildings are retrofitted with GSHP systems connecting the buildings with an ETP facilitates the recovery of waste energy produced when cooling one building to improve the efficiency of heat pumps in a building requiring space heating or domestic hot water. Figure 21 shows 5 buildings connected to the ETP (Buildings 1, 2, 8, 10 and 11). Buildings 2, 8 and 10

844 are cooling and increasing the temperature of the fluid in the ETP, while buildings 1 and 11 are extracting heat from the pipe.
 845 Waste energy from one building provides energy for the next, reducing reliance on energy transfer to and from GHX modules.
 846


847 Computer simulations indicate that the size and cost of GHX modules required for buildings taking advantage of energy
 848 transfer opportunities is reduced compared to that required for a separate GHX for each building as illustrated in Figure 20.
 849 Additional buildings are connected based on scheduled building renovations, upgrades, and budgets.
 850



851
 852 *Figure 21: An energy transfer pipe connects five buildings to enable the transfer of energy from one building to the next.*

853 Buildings being renovated are not necessarily located near one another and may be at opposite ends of the campus. It may
 854 be advantageous to create two district energy modules, each with a group of buildings, as seen in Figure 22. As the two
 855 district modules expand to include additional buildings, the modules can be linked with a pair of pipes that can facilitate the
 856 transfer of energy from one module to the other.
 857

858 This can be beneficial when one district energy module consists of heating dominant buildings such as residences with large
 859 domestic hot water requirements and the other includes primarily cooling dominant facilities such as a data center. The
 860 energy transfer link seen in Figure 22 enables the transfer of heat across the campus, while enabling the expansion of the
 861 system to optimize the needs of the buildings on campus.
 862



863
 864 *Figure 22: Illustrates the development of 2 separate district energy modules connected with an energy transfer link to transfer energy across the*
 865 *campus.*

866 **5.3. Summary**

867
 868 There are advantages to both district system configurations...a Central Energy Plant and the Single ETP distributed heat
 869 pump system. The following table summarizes the comparison between the two system approaches.

		Central Energy Plant	Single Energy Transfer Pipe
Mechanical system design	Pros	<ul style="list-style-type: none"> Maintenance of a single central energy plant may be more efficient and cost-effective than maintenance of distributed mechanical systems in numerous buildings. 	<ul style="list-style-type: none"> Mechanical systems in each building can be designed specifically for the needs of the building to maximize system efficiency. Buildings designed to operate with radiant floor heating and chilled beam cooling system operate more efficiently with heat pumps than buildings operating at higher and lower temperatures required with air-handling units. Buildings can be added to energy transfer pipe at any location without affecting system operation. Significantly lower initial infrastructure cost as system can grow and expand as required. This approach adapts readily to changes in development plans over time. Additional ground heat exchanger module may be required to accommodate additional building load but can be located adjacent to or under proposed new building.
	Cons	<ul style="list-style-type: none"> Requires full planning of future system to ensure central plant has capacity to meet heating and cooling demands of completed development, even though development build out may not be completed for several years. Requires higher initial construction cost for larger central energy plant and piping infrastructure. System delivers same water temperature to all buildings. The building with that requires the highest water temperature determines that temperature. Cannot take advantage of distribution system that can heat with low temperature water 	<ul style="list-style-type: none"> Distributed mechanical rooms may increase maintenance costs and require mechanical room space in each building.
Distribution system design	Pros		<ul style="list-style-type: none"> A single uninsulated pipe acts as an energy source and / or heat sink for heat pumps located in the buildings connected to it which results in lower initial capital cost. Connections to the energy transfer pipe (ETP) at regular intervals allows energy transfer to or from the ETP before each building or group of buildings. This allows a significant reduction in flow rates through the ETP and a corresponding reduction in pipe size and the pump power required to circulate the fluid through the pipe (Figure 18). Single energy transfer pipe operates at ground heat exchanger temperature and does not require insulation as delivery temperature to buildings is not critical. Fluid in energy transfer pipe operates at typical ground heat exchanger temperature within the operating parameters of high-density polyethylene pipe used for the GHX piping. Waste energy rejected to ETP from building operating in cooling mode becomes heat source for building downstream in heating mode or producing hot water.
	Cons	<ul style="list-style-type: none"> Hot and chilled water supply and return pipe pairs are required from central plant to each building (Figure 15) Distribution piping and circulation pumps must have the capacity to meet the combined peak heating and cooling loads of all buildings connected to system. Ground temperatures typically range from 45-50°F in Bemidji. To minimize heat transfer to the soil the distribution pipe requires insulation increasing construction cost. If hot water delivery temperatures are greater than 110-120°F, high-density polyethylene pipe cannot be used. Higher cost material will be required. 	
Ground heat exchanger design	Pros		<ul style="list-style-type: none"> GHX modules can be connected to ETP at numerous locations, allowing flexibility in GHX locations. GHX modules are designed to fit the land area available, minimizing the piping connecting them to the ETP, reducing construction cost, pipe sizes and fluid volumes.
	Cons	<ul style="list-style-type: none"> All GHX modules must be connected to the central energy plant. Depending on the land area available for construction on the GHX modules, piping connections may be long, increasing installation cost with increased pipe lengths and sizes as well as greater fluid volumes (Section 5.1). 	

Integration with other energy sources / heat sinks	Pros		<ul style="list-style-type: none"> Low-grade energy sources or cooling sources can be connected to ETP at any location. Renewable or waste energy resources can include solar thermal, waste heat from ice rink refrigeration system, combined heat and power, or wastewater energy recovery. Alternate heat sinks can include wastewater, sidewalk snow melt system and irrigation water (Section 5.2.2).
	Cons	<ul style="list-style-type: none"> Waste and renewable energy resources often provide only low-grade heat. For a central energy plant system to take advantage of low-grade energy they must be connected directly to the heat pumps in the central plant. When energy resources are not located near the central energy plant long piping connections may make it challenging to connect to the central energy plant to take advantage of them. 	
System expansion	Pros		<ul style="list-style-type: none"> The capacity of a single ETP is easily expanded by adding buildings and / or GHX modules to the pipe at almost any point around the ETP (Section 5.2.3). District energy modules can be linked to transfer energy from one district to another to take advantage of waste energy resources or to transfer energy to a heating dominant district from a cooling dominant district. This allows the transfer of energy across the entire system (Figure 22).
	Cons	<ul style="list-style-type: none"> The expansion of the system is determined by the heating and cooling capacity of the central energy plant, pump sizing and the design of the distribution system of the original system. If the central energy plant and distribution piping system have been designed to accommodate the anticipated capacity more buildings can be connected to the system. 	

870
871

872 6. System Implementation


873

874 The conversion of the BSU campus from a central energy plant fueled by natural gas for heating and water-cooled chillers for
875 cooling the buildings can be accomplished over an extended period. Critical design principles to incorporate immediately or
876 as soon as possible to insure GSHP feasibility remains cost effective in the future include:

- 877 • Implementation of ERV's on any anticipated AHU upgrade
- 878 • Implementation of AHU coils with additional capacity to accommodate lower hot water temperature (110°F)
- 879 • Ensure mechanical room renovations include allocated space for anticipated heat pump equipment

880

881 For the GSHP installation, the existing utility / pedestrian tunnels can potentially accommodate the piping for the ETP. The
882 tunnels are indicated in Figure 23, represented by the double red line. Piping that cannot be installed in the existing utility /
883 pedestrian tunnels can be installed with little disturbance on site with horizontal directional drilling techniques.



884
885
886


Figure 23: Campus buildings currently connected to the central energy plant with steam and chilled water piping in the utility / pedestrian tunnels and buried piping.



887
888

Figure 24: First step for the BSU geothermal conversion project.

889 Initial steps to reducing reliance on fossil fuels for heating can be taken with a retrofit of a GSHP system in Deputy Hall, with a
 890 HDD GHX located in the parking lot south of the Bangsburg Hall, as illustrated in Figure 24. Based on interviews with
 891 University personnel, Deputy Hall is one of the buildings most in need of mechanical system upgrades. Operation of the first
 892 building converted to a GSHP system provides an opportunity for facility operators to become familiar with a GSHP system.
 893
 894




895
896

Figure 25: Phase 1 ETP installation.

897
898
899
900
901
902
903


Next, Bangsburg Hall is converted, where initial steps are taken to facilitate energy sharing from one building to the next by connecting them with an ETP. The ETP can be installed in the existing utility / pedestrian tunnels up to Hagg-Sauer Hall. From the Hagg-Sauer Hall to the Heating Plant, the ETP is installed with horizontal drilling techniques to complete the single ETP loop. In the following years Bensen Hall and Hobson Memorial Union Buildings are connected to the ETP along with additional GHX modules constructed in the parking area south of Bangsburg Hall and under the football field at the Chet Anderson Stadium. The construction of the ETP is seen in Figure 25.



904
905

Figure 26: Initial steps for Phase 2 of the district geothermal energy system with the installation of an HDD GHX for the PE Complex.


906 Figure 26 shows the initial steps into the second phase of the district geothermal energy system with the installation of an
 907 HDD GHX for the PE Complex. Initially this facility will operate as a free standing GSHP system, unconnected to the ETP.
 908 Figure 27 shows the connection of the Gillett Wellness Center to the PE Complex along with the construction of an additional
 909 GHX module. Connecting the two mechanical systems is beneficial as the PE Complex is expected to be more heating
 910 dominant than the Gillette Wellness Center. Having the ability to share energy from one building to the other improves the
 911 energy balance to and from the GHX, reducing the size and cost of the GHX while improving system performance.
 912



913
 914 Figure 27: Phase 2 construction of the ETP connecting the Gillett Wellness Center with the PE Complex.

915 The PE Complex and Gillett Wellness Center are completed before several buildings in Phase 1 are connected to the ETP.
 916 As noted, the schedule is based on input from University staff and the need to upgrade the existing mechanical systems. After
 917 the Gillette Wellness Center and PE Complex are completed, several buildings in Phase 1 can be connected to the ETP.
 918 These include the Sattgast Hall and the AC Clark Library. Note that the site is somewhat constrained for construction of GHX
 919 modules in Phase 1.


920
 921 Figure 28 indicates that a vertical borehole GHX may be required when Sattgast Hall is connected to the ETP and that a
 922 water well or Darcy Well system is added when the AC Clark Library is connected to the system. As noted in Section 5.2.1, it
 923 is important to connect GHX modules at intervals between building or building groups to reduce the flow rate needed through
 924 the ETP. Limiting the flow rate reduces the size of the ETP as well as the size of the energy transfer pump needed on the
 925 ETP. Connecting GHX modules at intervals between building connections reduces initial construction cost while reducing
 926 pump power needed to operate the system.
 927



928

929 Figure 28: Sattgast Hall and the AC Clark Library connected to the Phase 1 ETP as well as a vertical GHX and water well heat exchanger.


930 The Central Receiving building is not connected to the existing central heating plant. When this building mechanical system
 931 requires renovation, it can be connected to the ETP for the third phase of the district geothermal energy system by extending
 932 the ETP to the Oak Hall building through the utility / pedestrian tunnels, as seen in Figure 29. After the ETP's in each of the
 933 three phases of the system are complete, district module link pipes are installed to take advantage of moving energy from one
 934 district module to another. The link pipes are also shown in Figure 29.
 935




936

937 Figure 29: Initial phases of the Phase 3 ETP construction.

938



939



940
941

Figure 30: BSU geothermal district system roadmap.

942 When the ETP in each of the phases is complete, remaining buildings are connected to the ETP when they are scheduled for
 943 renovation. As additional buildings are connected to the ETP, additional GHX modules may be required to ensure the
 944 temperature of the fluid in the system can be maintained. Figure 30 shows the three proposed phases of the district
 945 geothermal energy system with all currently existing buildings connected to one of the three ETP's.

946
 947 It is anticipated that the system will be constructed as buildings or building mechanical systems are renovated over the next
 948 10-30 years. When new buildings are planned for the campus, they can be integrated into the system by connecting it to the
 949 nearest ETP. The additional GHX capacity that will be needed to meet the additional energy loads of a proposed building will
 950 be dependent on the past performance of the system.

951

952 6.1. Performance and monitoring

953

954 Energy to heat and cool the buildings on the campus as it currently operates is delivered from an external source...a gas
955 pipeline and electrical grid. An external energy source can be considered as an infinite energy supply if the energy bill is paid.
956 The utility delivers as much energy as needed to meet the heating and cooling loads of the building(s). The only consequence
957 is the impact on the energy cost.

958

959 The operation of a GSHP and GHX is fundamentally different than the operation of a conventional system connected to an
960 external energy source. The earth should be considered more as an energy storage medium than an energy source. As heat
961 is extracted from the earth around the GHX piping, when the buildings are being heated, the temperature of the earth will
962 drop. As heat is rejected to the earth while the buildings are being cooled, the temperature of the earth increases.

963

964 Typically, a GHX is designed to deliver heat transfer fluid to heat pumps in the system within a specific temperature range.
965 Most commercially available heat pumps are manufactured to operate efficiently in the heating mode with fluid temperatures
966 ranging between 30-35°F and a maximum temperature of approximately 75-80°F. When operating in the cooling mode, they
967 are designed to operate efficiently at a minimum temperature of approximately 35-40°F and a maximum of 90-95°F. Outside
968 of those temperatures the heat pumps operate much less efficiently and they will eventually quit operating.

969

970 The performance of a GHX is calculated based on the following parameters:

971

- 971 • Thermal properties of the soil / rock in which the heat exchanger piping is installed
- 972 • Ambient soil temperature
- 973 • The influence of groundwater flow across the GHX piping
- 974 • The configuration and layout of the GHX piping relative to the surface of the earth and to other GHX piping
- 975 • The amount of heat extracted from the GHX relative to the amount of heat rejected to the GHX
- 976 • The instantaneous peak heating and cooling loads

976

977 The factors on which the design and performance of a GHX is based are based on inexact knowledge and on conditions that
978 change year to year.

979

- 979 • Geological conditions can vary on a site as large as the Bemidji campus.
- 980 • Calculated building energy loads are based on incomplete information
- 981 • Building use and occupancy schedules change throughout a typical year and may vary from one year to the next
- 982 • Weather changes from year to year
- 983 • The way a building is operated can change from year to year

983

984 With insufficient information about geological conditions and buildings and the variability of building use and occupancy,
985 weather and building operation from year to year, the amount of energy that is transferred to and from the ground can vary
986 significantly.

987

988 Changes during a single year generally create relatively small changes in the performance of a GHX because of the large
989 mass of earth and rock the pipe is in contact with, as long as the GHX design is well matched with the geology, GHX
990 configuration and calculated energy loads. Over the longer term, however, the cumulative change in temperature and GHX
991 performance is the greater concern.

992

993 Installing an energy meter on each GHX module and each building connection to the ETP allows full monitoring of the energy
994 loads to and from the GHX modules on an hourly basis. During the first year of operation the hourly energy loads are
995 compiled in a remote server. The hourly loads are used to calculate the performance of the GHX module for the upcoming
996 year (or years) into the future if the hourly energy loads remain the same. Continuous monitoring of the performance of the
997 GHX and predicting the performance into the future provides the information needed to:

998

- 998 • Optimize the performance of the GHX into the future, ensuring the fluid temperatures delivered to the heat pumps
999 stay within efficient operating parameters.
- 1000 • Verify the capacity of the GHX and calculate more accurately how much additional GHX is required to meet the
1001 requirements when additional buildings are connected to the system.
- 1002 • Validate the calculated heating and cooling energy loads of the buildings connected to the system.
- 1003 • Verify and optimize the flow rates required to meet the requirements of the heat pumps connected to the system.

999

1000

1001

1002

1003

1004 6.2. Discretionary loads

1005
1006 The ETP is designed to move energy, much like a conveyor belt. The primary purpose is to provide an energy source for
1007 buildings connected to it when they are being heated and to remove energy from them when they are being cooled. If too
1008 much energy is added to the “conveyor belt” ...if the temperature of the fluid in the ETP is higher than desired...excess heat
1009 is diverted to the GHX module(s). When the temperature in the ETP falls too low energy is drawn from the GHX.

1010
1011 Energy can be transferred to and from the ETP from many other sources. If temperature control is not required for the
1012 alternate energy sources, these are referred to as “discretionary loads”. Examples of discretionary loads can be used to add
1013 heat to the ETP include:

- 1014 • Fossil fuel boilers
- 1015 • Solar thermal panels
- 1016 • Waste heat from combined heat and power plants
- 1017 • Waste heat from refrigeration systems (ice rinks)
- 1018 • Heat recovered from wastewater (sewer lines)

1019 Discretionary loads that can be used to take heat from the ETP include:

- 1020 • Fluid coolers and cooling towers
- 1021 • Water used to irrigate sports fields
- 1022 • Sidewalk and driveway snowmelt systems
- 1023 • Water features (fountains)

1024 6.2.1. Auxiliary gas boilers

1025
1026 Gas (or other fossil fuels) are often used to add energy to a GSHP system to supplement the heating capacity of a GHX.
1027 Boilers are sometimes considered when the energy loads of the proposed system indicate that more energy will be removed
1028 from the ground than will be rejected to the ground on an annual basis. Reasons to consider an auxiliary boiler can include:
1029 • The land area available to build a GHX is cannot support the full loads of the building(s) connected to it
1030 • The cost of installing the GHX is greater than the available budget
1031 • Annual energy loads are very heating dominant (extract more energy from the GHX than is rejected to it), causing
1032 the temperature of the GHX to decrease in time

1033 An auxiliary heat source can be added at any location around the ETP, like the snowmelt system or solar thermal connections
1034 seen in Figure 19 to maintain the temperature of the fluid delivered to the heat pumps in the buildings.

1036 6.2.2. Wastewater energy transfer

1037
1038 The use of wastewater as a heat source/sink has been overlooked as an energy saving measure in modern day mechanical
1039 designs. Recent technologies have been developed for extracted and injecting heat into a wastewater line. Two new
1040 technologies include the *Sharc* wastewater system and the *@Source-Energy* pipe. The *@Source-Energy* pipe is a hollow
1041 concrete cylinder with a helical high-density polyethylene pipe embedded within the concrete pipe walls that has an outlet and
1042 inlet on each length of pipe, which are attached to a heat pump. Heat is captured from effluent in sanitary and storm sewer
1043 pipes, and from the adjacent ground. Since wastewater is constant at approximately 60°F year-round, energy for the district
1044 ETP can either be extracted or injected into the wastewater. This allows for complete control of the ETP and could drastically
1045 reduce the size/cost of the ground loops and ultimately increase the efficiency of the system.

1046
1047



Figure 31: Wastewater heat recovery system integrated with vertical GHX.

1048
1049

1050 This type of system would be most effective connected to the student residence buildings due to the relatively high
1051 wastewater flow rate compared to other buildings on campus. A recent study in Germany determined that 917 kWh/day of
1052 wastewater energy can be recovered from student residences by using a heat exchanger and heat pump system. Not only
1053 could this system reduce capital cost for reduced ground loop size, but also improve the efficiency of the system which would
1054 therefore increase annual cost savings and decrease CO₂ emissions. Since typical concrete sewage lines last between 50 to
1055 75 years and the student residence buildings at BSU were built from 1950-1970, the @Source-Energy pipe could be installed
1056 as a replacement to the existing sewage pipe. The cost difference between the @Source-Energy pipe and a conventional
1057 sewage pipe is assumed as negligible. Due to the anticipated reduction in operating costs from the heat extracted/injected to
1058 the @Source-Energy pipe; when BSU plans to replace the sewage pipes, it is strongly recommended to install the @Source-
1059 Energy pipe.

1060

1061 Another option is the *Sharc* system which can be installed where wastewater exits to the wastewater treatment plant and
1062 transfers heat from the wastewater to a holding tank connected to the ETP. The estimated cost of installing a *Sharc Energy*
1063 *Systems* wastewater energy transfer system in this development is estimated at approximately \$1,000,000. The benefit to this
1064 system is that it can be tied into the existing sewage pipe system.

1065

1066 6.2.3. Heat Rejection

1067

1068 Cooling towers are expensive and relatively useless other than their function of dissipating heat. Installing an ETP allows for
1069 the flexibility to dissipate heat with alternative means that are more useful. Irrigation lines for football fields, soccer pitches,
1070 and baseball diamonds can be integrated into the ETP system with a water-to-water heat exchanger to get rid of excess heat
1071 from the ETP when overheating (Figure 32). This allows for further control of the ETP and a useful dissipation of heat. This
1072 alternative is only available on the Chet Anderson Stadium, BSU Athletic Fields, and Soccer Complexes during May to
1073 October which is a limitation.

1074



Figure 32: Integration of energy transfer pipe with irrigation lines for football fields, soccer pitches, and baseball diamonds.

1075
1076

1077
1078
1079
1080
1081
1082

For the remainder of the year, snow melt systems can be utilized to act as a heat dissipation device that also reduces the need for paid snow removal. Piping is laid under sidewalks or parking lots and connected to the energy transfer loop (Figure 33). The piping can be installed when renovations are needed on the sidewalk or parking lots after years of deterioration. At this point, it would be worth installing snow melt systems if the economics make sense.



1083
1084

Figure 33: Integration of energy transfer pipe with piping under sidewalks and parking lots for snow melt.

1085
1086
1087
1088
1089
1090
1091
1092

6.2.4. Combined heat and power

Combined heat and power plants (CHP) burn fossil fuels or biomass to produce electricity. If 100 units of energy are consumed, the CHP produces approximately 30 units of electricity, 45 units of waste heat that is easily recovered, and 25 units of heat that is released to the atmosphere of exhaust gases, for an overall combined efficiency of approximately 75%. The waste heat of a CHP can potentially be connected to the energy transfer pipe and transferred to the buildings and / or GHX modules connected to the ETP.

1093
1094

7. Economics

1095
1096
1097
1098
1099

For this analysis, the main consideration is the incremental costs of the GHX, distribution piping, and efficiency measure upgrades. For the costs of the heat pump supply and installation, the price per ton was assumed as \$1,500. The advantage of a GSHP system is the gradual capital needed to retrofit one building at a time rather than spending a large amount of capital simultaneously for a boiler/chiller replacement for the entire campus.

1100
1101
1102
1103
1104
1105
1106
1107

The incentives were calculated by multiplying the building peak block load by 10% to account for installed heat pump capacity and building load diversity then multiplying by OTPCO incentive of \$1000/ton of installed equipment capacity. The lighting reduction incentive was assumed to be \$0.6 per watt/ft² saved. The incentives for the ERV's were not included but there is expected incentives based on the energy savings. The energy cost savings were calculated based on existing OTPCO rates and projected energy consumption as described in Section 3.5. The incremental costs and the additional energy costs savings have been broken into the recommended construction steps to allow for a modular build and higher probability of accepted funding.

1108
1109
1110

For the scenario without efficiency measures, the economic projections were deemed unfeasible due to the 40% increase in GHX size and cost.

1111
1112
1113
1114
1115
1116
1117
1118

When efficiency measures are added to the buildings, the incremental capital cost is \$10,006,269 which includes the projected costs of the ERV and lighting upgrades (Table 10). Since the efficiency measures decrease total energy usage, the energy cost savings are projected to be \$450,275 annually with \$202,575 attributed to the upgraded lights, \$66,888 attributed to the ERV and \$180,812 attributed to space heating and cooling once the project is complete. Although the ERV provides the lowest cost savings, it is required for an efficient GSHP system to create the high space heating and cooling cost savings. Based on these projections, the annual energy bill for BSU would decrease by 36%. Since the modular construction sequence allows for the accumulation of energy savings over each construction step, this allows for greater financial benefits.

1119
1120

Table 10: Estimated capital, energy costs savings and economic calculations broken into recommended construction steps with efficiency measure upgrades.

	Construction Steps	GHX Cost	Cooling Equipment Cost	ERV Cost	Lighting Upgrade Cost	Incentives	Incremental Capital Cost	Energy Cost Savings
A	Deputy Hall	\$440,748	\$297,000	\$157,312	\$0	\$184,800	\$710,260	\$30,304
B	Bangsburg Hall + Phase 1 ETP	\$333,382	\$235,950	\$173,756	\$86,878	\$147,876	\$682,090	\$25,877
C	Bensen Hall	\$100,188	\$141,900	\$106,684	\$53,342	\$99,503	\$302,611	\$17,344
D	Hobson Memorial Union	\$228,648	\$158,400	\$153,512	\$76,756	\$118,932	\$498,384	\$34,596
E	Heating Plant	\$23,184	\$47,850	\$40,634	\$20,317	\$34,814	\$97,171	\$5,967
F	Chet Anderson Stadium	\$0	\$7,500	\$900	\$450	\$5,162	\$3,688	\$90
G	PE complex + Phase 2 ETP	\$854,496	\$503,250	\$218,855	\$121,586	\$256,071	\$1,442,116	\$32,711
H	Gillett Wellness Center	\$577,080	\$448,800	\$171,530	\$0	\$212,300	\$985,110	\$28,942
I	Sattgast Hall	\$312,480	\$275,550	\$142,029	\$0	\$151,800	\$578,259	\$9,983
J	AC Clark Library	\$30,000	\$178,200	\$142,924	\$0	\$117,700	\$233,424	\$11,046
K	Central Receiving + Phase 3 ETP	\$144,556	\$34,650	\$16,160	\$8,080	\$21,609	\$181,837	\$2,739
L	American Indian Resource Center	\$79,380	\$31,350	\$20,776	\$10,388	\$20,240	\$121,654	\$2,837
M	Bridgeman Hall	\$84,420	\$85,800	\$0	\$33,772	\$59,458	\$144,534	\$9,884
N	Decker Hall	\$94,500	\$75,900	\$29,424	\$29,424	\$50,193	\$179,055	\$7,655
O	Memorial Hall	\$130,000	\$151,800	\$0	\$53,893	\$117,301	\$218,392	\$23,322
P	Walnut Hall	\$153,720	\$138,600	\$114,334	\$0	\$73,700	\$332,954	\$15,190
Q	Cedar Hall	\$124,740	\$92,400	\$78,266	\$39,133	\$56,988	\$277,551	\$15,145
R	Birch Hall	\$196,560	\$145,200	\$0	\$62,184	\$90,586	\$313,358	\$24,066
S	Linden Hall	\$214,200	\$146,850	\$135,130	\$67,565	\$94,723	\$469,022	\$25,274
T	Oak Hall	\$406,980	\$280,500	\$257,100	\$128,550	\$182,678	\$890,452	\$47,304
U	Tamarack Hall	\$278,460	\$206,250	\$176,820	\$88,410	\$128,628	\$621,312	\$34,215
V	Pine Hall	\$160,020	\$117,150	\$100,528	\$50,264	\$73,095	\$354,867	\$19,452
W	Hagg-Sauer Hall	\$265,860	\$240,900	\$0	\$0	\$138,592	\$368,168	\$26,335
	Total	\$5,233,602	\$4,041,750	\$2,236,674	\$930,992	\$2,436,749	\$10,006,269	\$450,275

1121
1122
1123
1124
1125
1126
1127
1128
1129
1130
1131
1132
1133
1134

The operator staffing required for a GSHP system is similar to a conventional steam boiler/chiller system. The incremental cost regarding maintenance and chemical water treatment of the existing boiler/chiller system was not included in Table 10, but is significant. BSU estimates that they currently spend \$3,500 to \$4,500 on boiler chemicals annually. The estimated annual cost difference for chemical water treatment between the existing system and anticipated GSHP system is \$2,000 based on the reduced make-up water from a tighter system.


Once the steam boilers are offline and the campus is fully retrofitted, water consumption is expected to reduce drastically. Throughout the heating season, BSU uses 700,000 to 800,000 gallons of water per year with their steam boilers. Therefore, if we assume a cost of \$5.55 per 1000 gallons (<https://www.bemidjipioneer.com/news/government-and-politics/4739087-Water-rate-increases-among-changes-in-citys-2020-fee-schedule>), BSU spends between \$3,885 - \$4,440 per year on water which would be eliminated if they switched to a GSHP system.

8. Environmental impact

1135
1136
1137
1138
1139

The environmental impact from CO₂ emissions is one of the main driving factors for this study. Based on the current natural gas and electricity consumption as well as the CO₂ emissions intensity for the OTPCO grid (1.69 lbs/kWh), the estimated current annual CO₂ emissions from BSU is 14,102 MT. The on-site CO₂ emissions strictly from natural gas are estimated at

1140 6,133 MT's. Electrifying the campus removes 98% of on-site CO₂ emissions and effectively eliminates all natural gas usage
 1141 (Figure 34).
 1142
 1143



1144 Figure 34: On-site CO₂ emission reductions per building construction step.
 1145

1146 Based on the methodology described in Section 3.5, the estimated total reduction in CO₂ emissions including the carbon
 1147 emission intensity from electricity once the full campus retrofit is complete is 42% to a total of 8,181 MT annually. The
 1148 reduction in CO₂ emissions will be gradual as more buildings are retrofitted. Based on the buildings previously prioritized in
 1149 Table 9, the step-by-step campus CO₂ emissions reduction can be seen in Figure 35. Since the district system is being
 1150 electrified, as the OTPCO electrical grid decreases its carbon emission intensity, the annual CO₂ emissions will decrease
 1151 proportionally.
 1152

1153 Since BSU is electrifying their campus, this allows for multiple avenues to continue reducing CO₂ emissions. OTPCO will
 1154 continue to reduce their CO₂ emissions from power generation by actively pursuing renewable energy technologies and
 1155 possible future regulations (mandates or carbon tax) may push electric utilities toward more aggressive adoption of
 1156 renewables. Another option for BSU is to purchase Renewable energy credits (RECs) which is the least costly way of
 1157 purchasing green electric power in the marketplace. Lastly, the installation of self-generation renewable technologies could
 1158 play a role in BSU's renewable energy goals if it is cost/space effective.
 1159
 1160




Figure 35: CO2 reductions - buildings with efficiency measures.

1161
1162

1163

8.1. Carbon Intensity

1164

1165

1166

1167

1168

1169

1170

1171

1172

1173

1174

1175

Currently, the OTPCO power grid is produced by coal-fired power plants that provide the largest share of the electricity generation at 46%. 38% is purchased from Midcontinent Independent System Operator, 14% is produced by wind power, 1% is produced by hydro power and 1% is produced from natural gas/oil. OTPCO currently has a carbon intensity of 1.69 lb/kWh and has committed to the continual reduction of their carbon intensity. OTPCO has recently commissioned a 150 MW wind farm and will be investing in a 50 MW solar plant in coming years. By 2022, their anticipated carbon intensity is projected to be 1.28 lb/kWh which is 24% lower than it currently stands as seen in Figure 36. OTPCO plans to add 250 MW of natural gas power in 2021 and 150 MW of wind power throughout the next decade. This investment will further reduce the carbon intensity and therefore decrease the offsite CO₂ emissions produced from BSU.




Figure 36: OTPCO projected carbon intensity through 2022.

1176
1177
1178

1179 8.2. Renewable Energy Credits

1180
1181
1182
1183
1184
1185
1186
1187
1188
1189

Renewable energy credits (RECs) are certificates that transfer the renewable energy portion of the electrical grid to the purchaser of the credit. A REC is produced when a renewable energy source generates one megawatt-hour (MWh) of electricity and delivers it to the grid. For example, if a wind power facility produces 5 MWh of electricity, they have 5 credits to either keep or sell. If BSU buys those credits, they are buying the “renewable” aspect of the electricity from the wind farm and can say that 5 MWh of their electricity use came from a renewable source. A REC that has been sold once cannot be purchased again and the exchange of RECs is tracked and recorded. All RECs are uniquely numbered and generally include information such as where they were generated, the type of renewable resource they came from, and a date stamp of generation.

1190
1191
1192
1193
1194

Currently, OTPCO sells RECs at a cost of \$0.54/MWh. Throughout the construction process of converting the BSU campus from natural gas to electricity, the cost of REC’s to eliminate CO₂ emissions from electricity consumption varies (Figure 37). At the end of the anticipated GSHP retrofit project, BSU can purchase \$5,700 worth of RECs annually, to offset the CO₂ emissions from their campus electricity consumption.




Figure 37: Annual cost of REC's to offset CO₂ emission from electricity consumption.

1195

1196

8.3. Carbon Tax

1197

1198

1199

1200

1201

1202

1203

1204

1205

1206

1207

1208

1209

1210

A carbon tax is not a matter of 'if', but a matter of 'when'. European countries such as Sweden, Switzerland, and Finland are leading the way with carbon taxes of 139, 101, and 77 USD/MT, respectively. The city of Boulder in Colorado became the first U.S. city to adopt a carbon tax in 2006 and since then has generated an average of \$1.8 million per year. A 2017 study conducted by the U.S. Department of the Treasury estimated that a tax of \$49/MT could raise roughly \$2.2 trillion in net revenues over 10 years from 2019 to 2028 (<https://www.treasury.gov/resource-center/tax-policy/tax-analysis/Documents/WP-115.pdf>).

BSU is currently producing 6,011 MT from on-site natural gas heating annually. If a carbon tax of \$40/MT is applied, this could cost BSU \$240,440 annually. Since carbon taxes have traditionally targeted building owners for on-site emissions, converting the campus to electricity would effectively eliminate all on-site emissions. Over the lifetime of the GSHP system (25 year), if the carbon tax remains constant, this carbon tax savings totals approximately \$6,011,000.

9. Closure

1211

1212

1213

1214

1215

1216

1217

1218

1219

1220

Converting the existing district heating and cooling system to a GSHP system is a step in the right direction for BSU and the State of Minnesota. A common misconception for geothermal systems is that they are risky and costly. To mitigate risk, a new technology has been developed that can monitor and predict the temperature of the ground based on the energy flowing into and out of it from sensors. Applying this system to the ground loops on campus would ensure a sustainable system for the anticipated lifespan.

Critical design principles to incorporate immediately or as soon as possible to insure GSHP feasibility remains cost effective in the future include implement ERV's on any anticipated AHU upgrade, implement AHU coils with additional capacity to

1221 accommodate lower hot water temperature (110°F), and ensure mechanical room renovations include allocated space for
1222 anticipated heat pump equipment.

1223
1224 The ETP is an opportunistic technology. Monitoring allows for assurance in optimal operation and the ability to determine
1225 whether adding discretionary loads could be lucrative rather than installing additional ground loop. Adding devices that can be
1226 used to divert energy away from a GHX like integrating into the irrigation system for fields or snowmelt systems can be more
1227 cost effective and useful than cooling towers. Incorporating surface water heat exchangers, wastewater heat exchangers or a
1228 Darcy Well system can also add or remove energy from a GHX in a cost-effective manner.

1229
1230 Working with BSU to provide the most cost-effective installation is the number one goal. Preliminary numbers show that
1231 installing a GSHP with efficiency measures is lucrative. The projected total incremental capital cost is \$10,006,269 with
1232 annual energy cost savings of \$450,275. The ETP allows for a modular type installation and the recommended construction
1233 steps allow for funding requests in smaller portions rather than a larger lump sum.

1234
1235 Electrifying the campus would eliminate 98% of on-site CO₂ emissions. Based on the analysis in Section 8, current
1236 greenhouse gas emissions are 14,102 MT annually and can be reduced to 8,181 MT based on the carbon emission intensity
1237 from electricity. As the OTPCO electrical grid becomes cleaner through increased production from renewable technologies,
1238 the reduction in CO₂ emissions will be proportional. Additionally, BSU can purchase \$5,700 worth of RECs to offset the CO₂
1239 emissions from their campus electricity consumption.

1240
1241 GEOptimize is prepared to work with local mechanical engineering firms, mechanical contractors, OTPCO, and BSU to
1242 provide and install an optimal system that maximizes CO₂ emissions reduction and energy consumption while minimizing
1243 capital cost. GEOptimize would be pleased to take this feasibility assessment a step further into detailed design to help shape
1244 a better future and set a benchmark for other establishments to reach for.